

Knauf Insulation d.o.o
Varazdinska
HR-42220 Novi Marof
Croatia

Date 07-04-2022
Init: MKL
E-mail: MKL@dbigroup.dk
Phone: +45 50 80 65 46

Summery Classification

This letter is to confirm that the following duct systems clad with Knauf Insulation Fire-teK are classified in accordance with EN 13501-3 as noted below:

Knauf Insulation Fire-teK WM 910 GGB:

Circular duct system based on Knauf Insulation Fire-teK WM 910 GGB, thickness 40 mm is classified as:

Fire resistance classification:	EI 30 (ve ho i ↔ o)	[Full classification]
Other fire resistance classifications:	EI 60 (ho o → i) S	[Only horizontal, type A]
	EI 45 (ve o → i)	[Only vertical, type A]
	E 30 (ve ho i ↔ o)	[Only integrity]

For full details of the circular duct system clad with Knauf Insulation Fire-teK WM 910 GGB, thickness 40 mm, one should refer to DBI Classification Report PCA10760A. **The classification is only valid if all the requirements listed in the Classification report PCA10760A are fulfilled, including the field of application.** This includes choice of specific materials and specific installation method.

Knauf Insulation Fire-teK WM 908 GGB:

Circular duct system based on Knauf Insulation Fire-teK WM 908 GGB, thickness 100 mm is classified as:

Fire resistance classification:	EI 120 (ve ho i ↔ o) S	[Full classification]
Other fire resistance classifications:	E 60 (ve ho i ↔ o) S	[Only integrity]

For full details of the circular duct system clad with Knauf Insulation Fire-teK WM 908 GGB, thickness 100 mm, one should refer to DBI Classification Report PCA10720A. **The classification is only valid if all the requirements listed in the Classification report PCA10720A are fulfilled, including the field of application.** This includes choice of specific materials and specific installation method.

Fire-teK WM 908 GGA:

Circular duct system based on Fire-teK WM 908 GGA, thickness 60 mm is classified as:

Fire resistance classification:	EI 30 (ve ho i ↔ o) S	[Full classification]
Other fire resistance classifications:	EI 60 (ho i ↔ o) S	[Only horizontal]
	E 60 (ho i ↔ o) S	[Only integrity, horizontal]
	EI 45 (ve o → i) S	[Only vertical, type A]
	E 30 (ve ho i ↔ o) S	[Only integrity]

For full details of the circular duct system clad with Fire-teK WM 908 GGA, thickness 60 mm, one should refer to FIRES Classification Report FIRES-CR-057-16-AUPE. **The classification is only valid if all the requirements listed in the**

Classification report FIRES-CR-057-16-AUPE are fulfilled, including the field of application. This includes choice of specific materials and specific installation method.

Circular duct system based on Fire-teK WM 908 GGA, thickness 80 mm is classified as:

Fire resistance classification:	EI 60 (ve ho i ↔ o) S	[Full classification]
Other fire resistance classifications:	EI 120 (ho o → i) S	[Only horizontal, type A]
	E 60 (ve ho i ↔ o) S	[Only integrity]

For full details of the circular duct system cladded with Fire-teK WM 908 GGA, thickness 80 mm, one should refer to FIRES Classification Report FIRES-CR-056-16-AUPE. **The classification is only valid if all the requirements listed in the Classification report FIRES-CR-056-16-AUPE are fulfilled, including the field of application.** This includes choice of specific materials and specific installation method.

Knauf Insulation Fire-teK BD 907 ALB

Rectangular duct system based on Knauf Insulation Fire-teK BD 907 ALB, thickness 60 mm is classified as:

Fire resistance classification:	EI 30 (ve ho i ↔ o) S	[Full classification]
Other fire resistance classifications:	EI 60 (ve o → i) S	[Only vertical, type A]
	E 30 (ve ho i ↔ o) S	[Only integrity]

For full details of the rectangular duct system cladded with Fire-teK BD 907 ALB, thickness 60 mm, one should refer to DBI Classification Report PCA10737A. **The classification is only valid if all the requirements listed in the Classification report PCA10737A are fulfilled, including the field of application.** This includes choice of specific materials and specific installation method.

This Summery Classification cannot be equated with a classification report based on EN 13501-3.

This Summery Classification is not under the scope of accreditation and are not valid to officially classify a product.

Danish Institute of Fire and Security Technology



Malthe Klint
M.Sc. (Eng.)